


FORM NO.

Certificate of Stability for Continued Use of School

1. Name of the Building: Choprajhar Green Valley Academy
2. Address: Dimrulla, Islampur, Dist: Uttar Dinajpur
3. Phone No. /Email: 8250505328 /greenvalleyisp@gmail.com
4. Name of the Occupier of the Premises: Choprajhar Green Valley Academy
5. Use of Occupancy: Academic Classes
6. No. of floors: 4 Storeyed
or

I certify that I have inspected the premises, the plans of which have been approved by the Proddhan of Panditpota-I Gram Panchyat of Islampur Block of Uttar Dinajpur dated 09.02.2021 and have reviewed it internally and externally. I am of the opinion that the structure of the said premises is apparently in sound condition though not tested technically. It is also found that the school has provided only one staircase though it has two nos staircases in the approved plan. Another staircase is under construction.

Attached is my Survey Report.


Signature:  09/2/21
Qualifications: **District Engineer**
Uttar Dinajpur Zilla Parishad
Experience: **Bachelor in C.E**

Affiliations/Memberships to Professional Associations:

Licence No. of Municipal Corporation (if not applicable, membership no of IIE)

Address:

Date:


PRINCIPAL
Choprajhar Green Valley Academy
Dimrulla, Islampur
Affiliation No.- 2430244


Manager
Choprajhar Green
Valley Academy

School Survey Form

1.	School Name	Choprajhar Green Valley Academy
2.	School ID	Affiliation no. 2430244. School Code 15575.
3.	School category (Pre-Primary - A, Primary- B, Secondary - C, Higher secondary - D)	Secondary - C Applied for Senior Secondary
4.	Address a) Location b) Village / Town / City : c) Census code: d) Taluka : e) District : f) Nearest Town	a) Islampur b) Islampur c) Unknown d) Dimrulla e) Uttar Dinajpur f) Kishanganj (Bihar)
5.	GPS Coordinates of School (Any center point)	Lat: N 26°14'22.182" Long: E 88°11'32.196"
6.	6. Communication system a) Telephone b) Fax c) Internet / Email d) Any other emergency communication facility	a) 8250505328 b) NA c) greenvallevisp@gmail.com d) Alternative mobile number: 9832065615
7.	School Area a) plot Area b) foot print area c) built up area	a) b) c) 642.55M ²
8.	Number of (Indicate as per shifts if any) a) pupils b) teachers c) other staff d) physically challenged staff	a) 662 b) 33 c) 37 d) 00
9.	Number of rooms a) classroom b) other rooms	a) 20 b) 12+11 toilets
10.	Passage and Veranda a) Width of passages (less than 1.5 m) b) Veranda Area (In m ²)	a) 2.55m ² b) 628.35m ² =(3 x71m x 2.55 m) + (1 x1.2 m x71m)
11.	Width of Stair flight (m)	1325 mm
12.	Number of Exit	02
13.	Compound wall (yes/No, if yes then height of the wall)	Yes ,12ft

(Signature)
District Engineer
Uttar Dinajpur Zilla Parishad

(Signature)
PRINCIPAL
Choprajhar Green Valley Academy
Dimrulla, Islampur
Affiliation No.- 2430244

(Signature)
Choprajhar Green
Valley Academy

14.	Year of Construction	2013
15.	Plan Shape: Draw plan and elevation with major dimensions.	
	<p>The elevation drawing shows a rectangular building with a height of 15.88m. The plan drawing shows a rectangular building with a width of 6.375m, a depth of 2.67m, and a total length of 71m.</p>	
16.	Plan Regular/Irregular (if irregular: T-Shap/L-Shape/ U-Shape/ Cruciform/other complex shape	Regular
17.	Number of storeys a) Basement (yes/No) b) Storeys c) Mezzanine (Yes/No)	a) No <i>m</i> b) 4 storeys c) No
18.	Typical storey height (m)	15.88 m
19.	Stilt at Ground Floor: (Yes/No)	No
20.	Type of load carrying system: a) Stone masonry bearing walls b) Brick Masonary Bearing walls c) RCC frames d) Steel structure e) Other (elaborate)	c) RCC Frames
21.	Partition walls Reinforced concrete/wood/masonry/mixed/ other(specify)	Masonry

ADV 09/12/21
District Engineer
Uttar Dinaipur Zilla Parishad


Banwari Choudhary
PRINCIPAL
Choprajhar Green Valley Academy
Dimrulla, Islampur
Affiliation No.- 2430244

[Signature]
Manager
Choprajhar Green
Valley Academy

22.	Floor slabs Reinforced/concrete/wood/ others (specify)	Concrete
23.	Floor finish: Wood /Ceramic/Mosaic/IPS/Other (specify)	Artificial stone flooring (1: 2: 4) 40 mm thick
24.	Roof : Reinforced concrete flat roof/reinforced concrete sloping roof/wood/asbestor/metal sheets/others (specify)	Reinforced concrete flat roof
25.	Seismic /other disaster safety features in the building(In case of masonry) a) Plinth Band b) Lintel Band c) Roof Band d) Other features Seismic /other disaster safety features In the building(In case of RC Frame) a) Proper framing grid of more than 3 frames of min. 3 bays each in both direction b) Max. cantilever projection(m) c) Any floating columns? If yes, give details.	a) yes b) No Cantilever c) No such structure
26.	Quality of building Workmanship Maintenance Grade on a scale of 5 (5 for excellent and 1 for poor)	5
27.	Any Existing Visible Damages (Yes/No) If Yes :Description	NO
28.	Last repair & construction works Repaired (Year) Strengthened (Year)	New Construction. So no such repair work is required.
29.	1. Fire Protection: (Yes/No) a) High voltage electric transformer not protected within campus or 25 m periphery of school. b) Loose electric wares within campus and not fenced c) Any highly flammable / hazardous goods lying in the school or surrounding buildings.	1. Yes a) NA b) NA c) NA



District Engineer
Uttar Dinajpur Zilla Parishad


Principal
Choprajhar Green Valley Aca.
Dimrulla, Islampur
Affiliation No.- 2430244



Manager
Choprajhar Green
Valley Academy

	<p>d) Petrol pump (25m periphery of school)</p> <p>e) Hydrants (Yes/No)</p> <p>f) Fire extinguishers (Yes/No)</p> <p>g) Fire alarms (Yes/No)</p> <p>h) Smoke detectors (Yes/No)</p>	<p>d) NA</p> <p>e) YES</p> <p>f) YES</p> <p>g) YES</p> <p>h) NO</p>
30.	<p>Surroundings of the school</p> <p>High rise /Low rise buildings/congested market area/ High traffic/ Low traffic area</p>	Low rise buildings
31.	<p>Technical documentation available</p> <p>Architecture (Yes/No)</p> <p>Structural design (Yes/ No)</p>	<p>Architecture Yes</p> <p>Structural design Yes</p>
32.	<p>Site – Soil conditions:</p> <p>Rock / Firm / Medium/ Soft</p>	Medium
33.	<p>Slope: Flat /Slight slope/Moderate slope/ Steep slope</p>	Flat
34.	<p>Seismic exposure: (To be filled by reviewing Engineer)</p> <p>Seismic Zone</p>	Zone- IV.
35.	<p>History of Disaster(Mention month, year, frequency and damages due to the disaster)</p> <p>Earth</p> <p>Cyclone</p> <p>Floods</p> <p>Fire</p>	NA
36.	<p>Awareness in School</p> <p>Among Teachers</p> <p>Among Students</p> <p>Any Formal Course/Training for disasters</p>	Yes , Yearly workshops are conducted for teachers ,students and other staffs.
37.	<p>Preparedness for disasters</p> <p>a) Contingency plan</p> <p>b) Escape routes</p> <p>c) Safe Shelters during cyclone</p> <p>d) Other preparedness</p>	Followed as per school curriculum


 District Engineer
 Uttar Dinajpur Zilla Parishad


 PRINCIPAL
 Choprajhar Green Valley Acad.
 Dimrulla, Islampur
 Affiliation No.- 2430241


 Manager
 Choprajhar Green
 Valley Academy

38.	Photographs	
39.	Remarks & recommendations (Yes/No)	Yes

The above parameters are indicated and interested consult may comment to achieve the objective of study.

Surveyor

Name : *Ashim Bhattacharya*

Signature : *[Signature]*
District Engineer
Uttaranchal Zilla Parishad

Date : *09/02/21*

Principal

Name : *Banani Anaguly*

Signature : *[Signature]*

Date : *09/02/2021*

Banani Anaguly
PRINCIPAL
Choprajhar Green Valley Academy
Dimrulla, Islampur
Affiliation No.- 2430244

[Signature]
Manager
Choprajhar Green Valley Academy



OFFICE OF THE
ISLAMPUR MUNICIPALITY

P.O. – ISLAMPUR: DIST. – UTTAR DINAJPUR

S.T.D. : 03526
Ph. : 255153, 258071 (O)
256954 (R)

Memo. No. 228/I.M./2021





Dated, Islampur the 11/02/2021


BUILDING SAFETY CERTIFICATE

This is to certify that the structural design of Choprajhar Green Valley Academy at Dimrulla, Islampur, Uttar Dinajpur, 733202, is safe & stable condition as per relevant BIS codes. I visited the site on 29/01/21. During inspection it is found the structural design has considered the seismic load as per relevant BIS guidelines.


11/02/21
Sub-Assistant Engineer
ISLAMPUR MUNICIPALITY
Islampur, Uttar Dinajpur.


11/02/21
Chairperson
Board of Administrator
Islampur Municipality
Islampur, Uttar Dinajpur


PRINCIPAL
Choprajhar Green Valley Academy
Dimrulla, Islampur
Affiliation No. - 2430291


12/02/21
Manager
Choprajhar Green
Valley Academy,

Office of the
PANDITPOTA - I GRAM PANCHAYAT

(UNDER ISLAMPUR DEV. BLOCK)

P.O. : Dimrulla :: P.S. : Islampur :: Dist. : Uttar Dinajpur

Memo No 295 | P-I G P | 2020

Date 02.12.2020

Ref No.CGVA/AUTH/11/20-21

Dated: 29/11/2020

SCHOOL BUILDING SAFETY CERTIFICATE

It is certified that building of the school named CHOPRAJHAR GREEN VALLEY ACADEMY, located at Dimrulla, Islampur, Uttar Dinajpur, 733202 (West Bengal) is in sound, safe and stable condition. I visited the site on 29/11/2020. RCC frame structure is there. Building materials which have been used are as per BIS norms and specifications. Building is earthquake resistant. Building is safe from all point of view. This certificate is provided to whom it may concern.

Dated: 29/11/2020

Place: Islampur

29/11/2020
Nirman Sahayak
Panditpota - I Gram Panchayat
Islampur Dev. Block, U/Dinajpur

[Signature]
Pradhan
Panditpota-I G.P.
Islampur Dev. Block

[Signature]
Manager
Choprajhar Green
Valley Academy

[Signature]
PRINCIPAL
Choprajhar Green Valley Academy
Dimrulla, Islampur
Affiliation No.- 2430244